

SOLUTIONS Incide Equate In the Years	AMP-2500	INNOVATIVE EQUIPMENT FOR HOT WATER SYSTEMS	Updated 8/7/2024
PO BOX 3244   LANCASTER, PA 17601		WWW.THERMALSOLUTIONS.COM	AMP2500-20240801

## AMP CONDENSING BOILERS - SUBMITTAL DATA SHEET

RATINGS AND CAPACITIES						
Input - Low fire:	500,000	BTU/HR				
Input - High Fire:	2,500,000	BTU/HR				
Output - High Fire:	2,425,000	BTU/HR				
Boiler Horsepower:	72.4	BHP				
Thermal Efficiency:	97.0%					
Low Fire Thermal Efficiency:	Up to 99%					
Heating Surface:	301	Sq.Ft.				
Water Content:	34.6	Gallons				
Fuel:	Natural Gas or LP Gas					
Firing Rate:	Full Modulation					
Burner Turndown:	5:1					
Low NOx Emissions:	< 10 ppm					
Inlet Gas Pressure (NG):	4" wc	Min.				
Inlet Gas Pressure (LP):	8" wc	Min.				
	14" wc	Max.				
Shipping Weight, Approximate:	2,038	Ibs				
ASME Section IV (Max 160 PSIG / 210°F)		[^As]				
Setpoint range is 60-185°F		<u>ل</u> تي ا				
Adjustable, manual reset high limit setting o						
ASME H stamp MAWT is 210°F for the vessel.	(For max setpoint, see Setpo	oint range.)				
ETL Certified to ANSI Z21.13 / CSA 4.9						
ETL Certified to UL 795 / CSA 3.1		Intertek				
DIMENSIONS / C	ONNECTIONS					
Height:	54 7/8"	(Note 1)				
Width:	46	(Note 2)				
Length:	75 5/8"	(Note 3)				
Supply Connection:	4" Grooved					
Return Connection:	4" Grooved					
Vent / Air Intake Connections:	10"					
Condensate / Boiler Drain Connection:	1"					
Gas Connection:	1 1/2" NPT					

FLOWS AND PRESSURE DROPS				
Delta T	Flow (GPM)	∆ P (F <del>1</del> . Hd)		
$20^{\circ}F \bigtriangleup T$	194	19.7		
$30^{\circ}F \bigtriangleup T$	129	10.5		
$40^{\circ}F \bigtriangleup T$	97	6.7		

**NOTES:** 1. Height dimension is from floor to top of jacket.

2. Length is from jacket front to jacket rear.


3. Dimensions shown are for reference only

# AMP CONDENSING BOILERS - SUBMITTAL DATA SHEET

STANDARD EQUIPMENT					
PRESSURE VESSEL DESIGN	1	BOILER	EQUIPMENT		
Stainless Steel Heat Exchanger		™ Control (24 Vac)			
ASME Section IV Certified, "H" Stamp	•	High Limit Temp Control, Manual Reset			
MAWP 160 PSIG & Max Temp 210°F		Low water cutoff, manual reset			
Setpoint range is 60-185°F		Water Flow Switch			
Adjustable, manual reset high limit setting of $\leq 200^{\circ}$ F.		Supply & Return Water Temperature Sensors			
ASME H stamp MAWT is 210°F for the vessel. (For max setpoint, see Setpoint range. Ten Year Limited Pressure Vessel Warranty	,	Flue Gas Temperature Sensor			
COMBUSTION DESIGN		Condensate trap Blocked Condensate Switch			
Stainless Steel Pre-Mix Burner		& Temperature Gauge			
Low NOx Emissions ( < 10 ppm)		ASME Relief Valve			
Full Modulation, 5:1 Turndown		(Available 30, 50, 60, 75,100, 125 or 150 psig)			
Natural Gas, Propane or Dual Fuel (Gas/Gas)	(Avalia)	ELECTRICAL DESIGN			
4" wc (8" wc Propane) to 14" wc inlet gas pressure	Models 1000				
Direct Spark Ignition System with UV Scanner		230VAC/60HZ/1PH - High Vc	ltage		
High/Low gas pressure switches, manual reset		(1500 to 2500 - Optional 208-230-460VAC/60HZ/3PH)			
Zero governor gas valve	Models 3000				
Variable Speed Combustion Blower		- 208-230-240VAC/60HZ/1PH - High Voltage			
Air Proving Switch		- 208-230-240-460VAC/60HZ/3PH - High Voltage			
Blocked Vent Switch		Models 3500-4000:			
Manual fuel changeover switch (Dual Fuel Only)		- 208-230-240-460VAC/60HZ/3PH - High Voltage			
VENTING	- PCB (Printed Circuit Board) Fused Connections				
Category II or IV Venting					
Indivdual or Common (Engineered) Vent System	- EMS Con	- EMS Communications			
Vertical or Horizontal	(Dual RJ4	(Dual RJ45 Jacks for Peer-To-Peer or ModBus)			
CPVC, PP or SS Venting *Materials Acceptable		- Boiler Options (Sensors)			
Combustion Air Intake - Sealed or Room	- Pumps (E	- Pumps (Boiler, DHW, System) & Auxiliary Devices			
* Flue system material shall be capable of continuous operation at 210°F or higher and shall be certified to	o UL 1738 – venting system for gas-bu	rning appliances cat II, III and IV.			
OPTIC	ONAL EQUIPMENT				
Hydronic Kit (Boiler Circulation Pump, Pump Flange Kit and Condensate Ne	eutralizer)				
External High Limit Temperature Control, Manual Reset					
Condensate Neutralizer					
Supply Header Temperature Sensor:	Direct Immersion	Well Immersion (with We	ell)		
Outdoor Air Temperature Sensor:	Wired	Wireless			
EMS Signal Converter Kit (Converts Energy or Building Management System	n 0-10v signal to 4-20mA)				
Motorized Isolation Valves					
Alarm Buzzer with Silencing Switch					
Gas Valve Proving Switch					
Vent Adapter - CPVC					
Universal Communications Gateway (BACnet, Metasys, Modbus or Lonwor	rks)				
Stackable Rack					
Conductor Sequencing Panel					
The Conductor manages multiple condensing & non-condensing, small & large heat output, new and the right boiler to match operating conditions. The Conductor offers a single point boiler plant Energy add for the separate Lonworks gateway.					
Extended Warranty					
3-Year Parts 5-Year Parts	10-Year Parts	5-Year Parts/Labor	10-Year Parts/Labor		

## **AMP CONDENSING BOILERS - SUBMITTAL DATA SHEET**

CONCERT CONTROL FEATURES



## Dashboard - Color Touchscreen Display, 4"

Intuitive Icon Navigation "Quick" Setup Menus \*Real Time BTU/H Display

#### Two (2) Temperature Demand Inputs

Outdoor Air Reset Curve for Each Input

Time of Day Setback Capability (Enviracom Thermastat must be installed)

## Three (3) Pump Control

Boiler Pump With On/Off or Variable Speed Control Domestic Hot Water (DHW) Pump System Pump Alternative Control to Combustion Air Damper or Standby Loss Damper

Pump Overun for Heat Dissipation

Pump Exercise

Pump Rotor Seizing Protection

#### Peer-to-Peer Boiler Communications

Multiple Size Boiler Sequencing Up to 8 Units \*Two (2) Boiler Start/Stop Trigger

Lead Boiler Automatic Rotation

## Energy Management System (EMS) Interface

\*Firing Rate and Water Temperature Based Algorithms for Multiple Boilers; loss of EMS signal defaults to local boiler settings
420mAdc Input/Output (010Vdc Optional Converter) ModBus Input/Output (BACnet or LonWorks Optional Gateway)
Simultaneous Interface with PeertoPeer

### USB Data Port Transfer

Upload Settings Between Boilers Download Parameters for Troubleshooting Import Data into .CRV Formatted Files for Performance Analysis \* Unique to Concert



## Energy Efficiency Enhancer

AntiCycling Technology Multipler boiler base load common rate Outdoor Air Temperature Reset Curve Warm Weather Shutdown Boost Temperature & Time Ramp Delay OverTemperature Safeguarding Self-Guiding Diagnostics

Identifies Fault

Describes Possible Problems Provides Corrective Actions

Time/Date Stamp on Alarms and Lockouts

### Unmatched Archives

Historical Trends Collects Up to 4 months Data Event History Up to 3000 Alarms, Lockouts and Cycle & Run Times Alarm Limit String Faults, Holds, Lockouts and Others Cycle & Run Time Boilers & Pumps Resettable (Lockouts/Alarms/Cycles & Run Time)

### **Domestic Hot Water Priority**

DHW Tank Piped With Priority in the Boiler Loop DHW Tank Piped as a Zone in the System With the Pumps Controlled by the Concert Control DHW Modulation Limiting Status Screens Sensor Monitoring and Control **Other Features** Factory Default Settings

Three Level Password Security Frost Protection Contractor Contacts (Up to 3) Low Water Flow Safety Control & Indication

Proportion Integral Derivative (PID) Parameters for

Central Heat, DWH, Sequencer and Fan

Built-in Brown-Out Protection