

THERMAL® SOLUTIONS LOCATION S LOCATION TO HAVE Spaten	AMPW-1000	INNOVATIVE EQUIPMENT FOR HOT WATER SYSTEMS	Updated 6/19/24	
PO BOX 3244 LANCASTER, PA 17601		WWW.THERMALSOLUTIONS.COM	AMPW1000-20240602	

RATINGS AND CAPACITIES				
Input - Low fire:	200,000	BTU/HR		
Input - High Fire:	999,000	BTU/HR		
Output - High Fire:	979,020	BTU/HR		
DHW Recovery (40°F to 140° Rise):	1,176	GPH		
Thermal Efficiency:	98.0%			
Heating Surface:	100.2	Sq.Ft.		
Water Content:	11.0	Gallons		
Fuel:	Natural Gas or LP Gas			
Firing Rate:	Full Modulation			
Burner Turndown:	5:1			
Low NOx Emissions:	< 10 ppm			
Inlet Gas Pressure (NG):	4" wc	Min.		
Inlet Gas Pressure (LP):	8" wc	Min.		
	14" wc	Max.		
Shipping Weight, Approximate:	922	lbs		
ASME Section IV (Max 160 PSIG / 210°F)				
) w		




(NSF)

Setpoint range is 60-185°F

Adjustable, manual reset high limit setting of ≤ 200°F.

ASME HLW stamp MAWT is 210°F for the vessel. (For max setpoint, see Setpoint range.)



NSF/ANSI Standard 372

DIMENSIONS / CONNECTIONS				
Height:	42-3/4"	(Note 1)		
Width:	34-1/4""	(Note 2)		
Length:	45-1/2"	(Note 3)		
Supply Connection:	3" Grooved			
Return Connection:	2-1/2''' Grooved			
Vent / Air Intake Connections:	8"			

1" NPT

Gas Connection: 1'

NOTES: 1. Height dimension is from floor to top of jacket.

- 2. Length is from jacket front to jacket rear.
- 3. Dimensions shown are for reference only

FLOW REQUIREMENTS				
Water Hardness	Flow (GPM)	r P (Ft. Hd)		
4 - 12 gpg	66	7.4		
12 - 15 gpg	88	12.3		



STANDARD EQUIPMENT							
PRESSURE V	/ESSEL DESIGN			BOILER E	QUIPMENT		
Stainless Steel Heat Exchanger			Concert ™ C	Control (24 Vac)			
ASME Section IV Certified, "HLW" Stamp (1000 - 2000)			High Limit Temp Control, Manual Reset				
ASME Section IV Certified, "H" Stamp (2500 - 4000)			Low water cutoff, manual reset				
MAWP 160 PSIG & Max Temp 210°F			Water Flow S	Switch			
Setpoint range is 60-185°F			Supply & Return Water Temperature Sensors				
Adjustable, manual reset high limit setting of ≤ 200°F.			Flue Gas Temperature Sensor				
ASME HLW stamp MAWT is 210°F for the vess	ASME HLW stamp MAWT is 210°F for the vessel. (For max setpoint, see Setpoint range.)			Condensate trap			
Five Year Limited Heat Exchanger Warranty			Blocked Condensate Switch				
Ten Year Limited Pressure Vessel Warranty			Pressure & Te	emperature Gauge			
COMBUST	TION DESIGN		ASME Tempe	erature & Pressure Safety Relief Val	lve, 150 psi		
Stainless Steel Pre-Mix Burner				ELECTRIC	AL DESIGN		
Low NOx Emissions (< 10 ppm)			Models 1000-2	<u>2500:</u>			
Full Modulation, 5:1 Turndown			- 120-208-230V	/AC/60HZ/1PH - High Voltage			
Natural Gas, Propane or Dual Fuel (Gas/Gas)			(1500 to 2500) - Optional 208-230-460VAC/60HZ/	/3PH)		
4" wc (8" wc Propane) to 14" wc inlet gas pres	ssure		Models 3000:				
Direct Spark Ignition System with UV Scanner			- 208-230-240V	/AC/60HZ/1PH - High Voltage			
High/Low gas pressure switches, manual rese	t		- 208-230-240-4	460VAC/60HZ/3PH - High Voltage			
Zero governor gas valve			Models 3500-4000:				
Variable Speed Combustion Blower			- 208-230-240-460VAC/60HZ/3PH - High Voltage				
Air Proving Switch			- PCB (Printed Circuit Board) Fused Connections				
Blocked Vent Switch			24VAC/5VDC - Low Voltage PCB				
Manual fuel changeover switch (Dual Fuel O	nly)		- EMS Communications				
<u>VE</u>	<u>NTING</u>		(Dual RJ45 Jo	acks for Peer-To-Peer or ModBus)			
Category II or IV Venting			- Boiler Option	ns (Sensors)			
Indivdual or Common (Engineered) Vent System			- Pumps (Boiler, DHW, System) & Auxiliary Devices				
Vertical or Horizontal							
CPVC, PP or SS Venting *Materials Acceptable	е						
Combustion Air Intake - Sealed or Room							
* Flue system material shall be capable of continuo	ous operation at 210°F or higher and shall be certific	ed to UL 1738 – venting s	rstem for gas-burn	ning appliances cat II, III and IV.			
	0	PTIONAL EQUI	PMENT				
External High Limit Temperature	Control Manual Reset						
	Cormol, Marioar Reser						
Condensate Neutralizer							
Hot Water Header Temperature	e Sensor:	Direct Imm	ersion	Well Immersion (with Well)			
EMS Signal Converter Kit (Conve	erts Energy or Building Management System 0-	10v signal to 4-20mA)					
Alarm Buzzer with Silencing Swit	ch						
Gas Valve Proving Switch							
Vent Adapter - CPVC							
	eway (BACnet, Metasys, Modbus or Lonworks)						
Stackable Rack	, (
Conductor Sequencing Panel							
The Conductor manages multiple cond	ditions. The Conductor offers a single point boiler plant Er				helps improve system efficiency by selecting and modulating SACnet/IP and BACnet MSTP standard. If Lonworks needed,		
Extended Warranty							
3-Year Parts	5-Year Parts	10-Year Part	5	5-Year Parts/Labor	10-Year Parts/Labor		

CONCERT CONTROL FEATURES



Dashboard - Color Touchscreen Display, 4

Intuitive Icon Navigation

"Quick" Setup Menus

*Real Time BTU/H Display

Temperature Demand Inputs

Time of Day Setback Capability

(Enviracom Thermastat must be installed)

Two (2) Pump Control

System Pump

Alternative Control to Combustion

Air Damper or Standby Loss Damper

Pump Overun for Heat Dissipation

Pump Exercise

Pump Rotor Seizing Protection

Pump Overun for Heat Dissipation

Peer-to-Peer Boiler Communications

Multiple Size Boiler Sequencing Up to 8 Units

Lead Boiler Automatic Rotation

Energy Management System (EMS) Interface

*Firing Rate and Water Temperature Based

Algorithms for Multiple Boilers; loss of EMS

signal defaults to local boiler settings

420mAdc Input/Output (010Vdc Optional Converter)

ModBus Input/Output (BACnet or LonWorks

Optional Gateway)

Simultaneous Interface with PeertoPeer

USB Data Port Transfer

Upload Settings Between Boilers

Download Parameters for Troubleshooting

Import Data into .CRV Formatted Files for Performance Analysis

* Unique to Concert



Energy Efficiency Enhancer

AntiCycling Technology

Multipler boiler base load common rate

Boost Temperature & Time

Ramp Delay

OverTemperature Safeguarding

Self-Guiding Diagnostics

Identifies Fault

Describes Possible Problems

Provides Corrective Actions

Time/Date Stamp on Alarms and Lockouts

Unmatched Archives

Historical Trends Collects Up to 4 months Data

Event History Up to 3000 Alarms, Lockouts and Cycle & Run Times

Alarm Limit String Faults, Holds, Lockouts and Others

Cycle & Run Time Boilers & Pumps

Resettable (Lockouts/Alarms/Cycles & Run Time)

Other Features

Factory Default Settings

Three Level Password Security

Frost Protection

Contractor Contacts (Up to 3)

Low Water Flow Safety Control & Indication

Proportion Integral Derivative (PID) Parameters for

DWH, Sequencer and Fan

Built-in Brown-Out Protection