



- A. No further apart than 12 inches for four pipe diameter), whichever is smaller.
- B. Keep this distance as short as practical.
- C. At least 18" of straight pipe for Conventional Air Scoop.

REV: A	EN: 83-560-8500	DATE: 11/12/2013	DWN: E.JL	CHKD:	APPD:	APPD:
INITIAL RELEASE.						
REFERENCE ASME Y14.5M-1994 FOR GEOMETRIC TOLERANCES. ALL DIMENSIONS IN INCHES. DRAWING NOT TO BE SCALED. NON-BASIC DIMENSIONAL AND ANGULAR TOLERANCES UNLESS OTHERWISE NOTED:						
DECIMALS: X.X - ±0.1, X.XX - ±0.03, X.XXX - ±0.005. FRACTIONAL: ±1/32. ANGULAR: ±1°						
THIS DOCUMENT CONTAINS CONFIDENTIAL INFORMATION WHICH IS THE PROPERTY OF THERMAL SOLUTIONS LLC. THIS DOCUMENT MAY NOT BE REPRODUCED, TRANSFERRED OR USED, OR ITS CONTENTS DISCLOSED, WITHOUT THE WRITTEN PERMISSION OF THE OWNER.						
FIRST USE APEX(TS)			MATERIAL			
PROPERTY OF Thermal Solutions Products LLC			TITLE MODULAR BOILER WATER PIPING			
DRAWING NUMBER TS-83-151			SCALE NONE	DWG SIZE C	SHEET 1 OF 1	
LANCASTER, PA 17604-3244						