



A. No further apart than four pipe diameters (or 12 inches), whichever is smaller.
 B. Keep this distance as short as practical.
 C. At least 18" of straight pipe for **Conventional** Air Scoop.

| | | | | | | |
|---|-----------------|------------------|---|---------------|-----------------|-------|
| REV: A | EN: 83-560-8500 | DATE: 11/13/2013 | DWN: E.JL | CHKD: | APPD: | APPD: |
| INITIAL RELEASE. | | | | | | |
| REFERENCE ASME Y14.5M-1994 FOR GEOMETRIC TOLERANCES. ALL DIMENSIONS IN INCHES. DRAWING NOT TO BE SCALED. NON-BASIC DIMENSIONAL AND ANGULAR TOLERANCES UNLESS OTHERWISE NOTED: DECIMALS: X.X - ±0.1, X.XX - ±0.03, X.XXX - ±0.005. FRACTIONAL: ±1/32. ANGULAR: ±1° | | | | | | |
| THIS DOCUMENT CONTAINS CONFIDENTIAL INFORMATION WHICH IS THE PROPERTY OF THERMAL SOLUTIONS LLC. THIS DOCUMENT MAY NOT BE REPRODUCED, TRANSFERRED OR USED, OR ITS CONTENTS DISCLOSED, WITHOUT THE WRITTEN PERMISSION OF THE OWNER. | | | | | | |
| FIRST USE APEX(TS) | | | MATERIAL | | | |
| PROPERTY OF Thermal Solutions Products LLC | | | TITLE NEAR BOILER PIPING HEATING PLUS INDIRECT WATER HEATER | | | |
| DRAWING NUMBER LANCASTER, PA 17604-3244 TS-83-152 | | | SCALE NONE | DWG SIZE C | SHEET 1 OF 1 | |